

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0067:203 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd,  
Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

**DESIGN:** Models FP-11, HFP-11 analog and FPO-11 photoelectric type smoke detectors. Models FP-11 and HFP-11 also have a supplemental 135°F heat sensor. Model \*DGH-11 detector guard housing. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. These detectors are intended for installation on a vertical wall surface or the ceiling. They are also acceptable for duct application with an air velocity of 0-4000 ft/min. when used with Models DB-11, DB-HR or DB-X11RS bases.

**MARKING:** Listee's name or Cerberus Pyrotronics, model number and UL label.

**APPROVAL:** Listed as photoelectric type smoke detectors for use with listee's separately listed base Model DB-11, \*DB-HR or DB-X11RS (CSFM Listing No. 7300-0067:134) and separately listed compatible fire alarm control units. \*Model DGH-11 detector guard housing is listed for use only with FP-11 and HFP-11.

\*Rev. 08-28-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 28, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**